Dewatering, Bunker Hill Basin R8-2004-0009

To Be Put into CDF Template:

M-001

Flow	1 / Day	GPD
Total Suspended Solids (TSS)	1 / Month	mg/L
pH	1 / Month	SU
рН	1 / Month	SU
Nitrate, Total (as NO3)	1 / Month	mg/L
Total Dissolved Solids (TDS)	1 / Month	mg/L

M-002

Flow	1 / Day	GPD
Total Suspended Solids (TSS)	1 / Month	mg/L
рН	1 / Month	SU
рН	1 / Month	SU
Nitrate, Total (as NO3)	1 / Month	mg/L
Total Dissolved Solids (TDS)	1 / Month	mg/L

M-003

Flow	1 / Day	GPD
Total Suspended Solids (TSS)	1 / Month	mg/L
рН	1 / Month	SU
рН	1 / Month	SU
Nitrate, Total (as NO3)	1 / Month	mg/L
Total Dissolved Solids (TDS)	1 / Month	mg/L

M-004

Flow	1 / Day	GPD
Total Suspended Solids (TSS)	1 / Month	mg/L
рН	1 / Month	SU
рН	1 / Month	SU
Nitrate, Total (as NO3)	1 / Month	mg/L
Total Dissolved Solids (TDS)	1 / Month	mg/L

M-005

Flow	1 / Day	GPD
Total Suspended Solids (TSS)	1 / Month	mg/L
рН	1 / Month	SU
рН	1 / Month	SU
Nitrate, Total (as NO3)	1 / Month	mg/L
Total Dissolved Solids (TDS)	1 / Month	mg/L

M-006

Flow	1 / Day	GPD
Total Suspended Solids (TSS)	1 / Month	mg/L

```
pH 1 / Month SU pH 1 / Month SU Nitrate, Total (as NO3) 1 / Month mg/L Total Dissolved Solids (TDS) 1 / Month mg/L
```

M-007

Flow 1 / Day GPD
Total Suspended Solids (TSS) 1 / Month mg/L
pH 1 / Month SU
pH 1 / Month SU
Nitrate, Total (as NO3) 1 / Month mg/L
Total Dissolved Solids (TDS) 1 / Month mg/L

M-008

Flow 1 / Day GPD
Total Suspended Solids (TSS) 1 / Month mg/L
pH 1 / Month SU
pH 1 / Month SU
Nitrate, Total (as NO3) 1 / Month mg/L
Total Dissolved Solids (TDS) 1 / Month mg/L

Narrative:

N/A

Pre-Calculated:

M-001

Total Dissolved Solids (TDS)<=300.0* mg/L, Limit Basis: Other, Sampling Frequency: 1 / Month, Sampling Type: Grab. (final requirement effective since the beginning of this regulatory measure to the end of this regulatory measure) [All Year] The 12-month average flow-weighted TDS discharge shall not exceed 300 mg/L.

M-002

Total Dissolved Solids (TDS)<=400.0* mg/L, Limit Basis: Other, Sampling Frequency: 1 / Month, Sampling Type: Grab. (final requirement effective since the beginning of this regulatory measure to the end of this regulatory measure) [All Year] The 12-month average flow-weighted TDS discharge shall not exceed 400 mg/L.

M-003

Total Dissolved Solids (TDS)<=400.0* mg/L, Limit Basis: Other, Sampling Frequency: 1 / Month, Sampling Type: Grab. (final requirement effective since the beginning of this regulatory measure to the end of this regulatory measure) [All Year] The 12-month average flow-weighted TDS discharge shall not exceed 400 mg/L.

M-004

Total Dissolved Solids (TDS)<=650.0* mg/L, Limit Basis: Other, Sampling Frequency: 1 / Month, Sampling Type: Grab. (final requirement effective since the beginning of this regulatory measure to the end of this regulatory measure) [All Year] The 12-month

average flow-weighted TDS discharge shall not exceed 650 mg/L.

M-005

Total Dissolved Solids (TDS)<=700.0* mg/L, Limit Basis: Other, Sampling Frequency: 1 / Month, Sampling Type: Grab. (final requirement effective since the beginning of this regulatory measure to the end of this regulatory measure) [All Year] The 12-month average flow-weighted TDS discharge shall not exceed 700 mg/L.

M-006

Total Dissolved Solids (TDS)<=700.0* mg/L, Limit Basis: Other, Sampling Frequency: 1 / Month, Sampling Type: Grab. (final requirement effective since the beginning of this regulatory measure to the end of this regulatory measure) [All Year] The 12-month average flow-weighted TDS discharge shall not exceed 700 mg/L.

M-007

Total Dissolved Solids (TDS)<=700.0* mg/L, Limit Basis: Other, Sampling Frequency: 1 / Month, Sampling Type: Grab. (final requirement effective since the beginning of this regulatory measure to the end of this regulatory measure) [All Year] The 12-month average flow-weighted TDS discharge shall not exceed 700 mg/L.

M-008

Total Dissolved Solids (TDS)<=700.0* mg/L, Limit Basis: Other, Sampling Frequency: 1 / Month, Sampling Type: Grab. (final requirement effective since the beginning of this regulatory measure to the end of this regulatory measure) [All Year] The 12-month average flow-weighted TDS discharge shall not exceed 700 mg/L.

Raw Data:

N/A